



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 09/08/2025

Area: IOSA

| Equipment     | Job  |
|---------------|--|
| WOBR- L and T | TRIAL RUN DONE AND CHECKED THE LT SPEEDS IN DRIVE AND PROGRAM.               |
| OC-19A        | PPM DONE ON MOTOR AND FIELD DEVICES  |
| WOBR-L and T  | LT PROGRAMMING CHECKING FOR MOTOR HEATERS AND PTC FOR EACH INDIVIDUAL MOTORS |
| LBDS-2        | HOUSE KEEPING DONE IN FIRST FLOOR  |
| MISC          | OC-19A,25A,29A,31A,33A,36A,37A PJB INSPECTION AND MAINTENANCE DONE.          |