



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 12/07/2025

Area: CHP

| Equipment   | Job  |
|-------------|--|
| Misc        | cc-53 spare motor shifted to 53 level  |
| Lighting    | SCR-10 cabin to yard focussing light fixed, CM-19 and JH-19 road focus lighting done |
| SCR-8       | CCR communication healthy bit programmed and tested                                  |
| Lighting    | CC-34 and 35 T/E lighting defects rectified  |
| CC-34,SCR-2 | ppm done   |
| CC-34,SCR-2 | TUL chute sensor and discharge chute sensor modification done with polymer sheets    |