



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 14/06/2025

Shift: B

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 25	olr acted	reset	19:00:00	19:10:00	
2	CHP	CC 131	olr acted	reset	21:00:00	21:05:00	
3	CHP	CC 131	zss acted,cage stucked due to stone	stone removed	18:00:00	18:10:00	
4	CHP	cc 39 SCR7	TUL C/ SENSOR acted,cable got cut	cable jointed	20:10:00	20:17:00	
5	CHP	CC 32 scr5	Lt not working,mpcb 3 tripped	made it on	19:20:00	19:35:00	
6	CHP	CC 105 scr 10	lighting not working,lighting mcb tripped	mcb made on	19:00:00	19:10:00	
7	CHP	CC 111 S3	luffing not working,plc power is in off,slew not working	plc power made on,slew potentiometer adjusted	17:18:00	17:30:00	
8	CHP	CC 105 scr 10	luffing not working,in plc glass relay RB1,2 and 3 not connected properly	rb1 ,2 and 3 pressed manually	15:50:00	16:05:00	
9	CHP	CC 39 SCR 7	LT not taking place,control high loop loose connection	loop tightened	15:22:00	15:50:00	