



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 19/11/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR ON CO-25	REPORTED LT NOT TAKING PLACE FOUND M-1TRIP	RESET DONE	09:00:00	09:20:00	
2	CHP	CC-117	OLR ACTED	RESET DONE	08:20:00	08:25:00	
3	CHP	CC-51	FEEDING CONVEYOR MPD TRIP (6 TIMES)	RESET DONE	07:30:00	13:15:00	
4	CHP	CC-54	OLR ACTED (2 TIMES )	RESET DONE	12:20:00 12:40:00	12:25:00 12:45:00	
5	WT	OT-5	REPORTED NOT MOVE FOUND DRIVE-2 TRIP	RESET DONE	07:10:00	07:15:00	
6	WT	OT-3	REPORTED NOT ROTATE FOUND DRIVE-1 TRIP PGF-3 FAULT	RESET DONE	09:25:00	09:30:00	