



वी.एस.पी  
VSP

# RASTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 24/06/2025

Area: IOSA

Equipment	Job
OC-17A	RUNNING INSPECTION DONE. CURRENTS AND TEMPERATURES RECORDED.
ENGINEERING STATION	ENGG.STN IN CONSTN OFFICE IS NOT PINGING WITH 3.0.0.X NETWORK NOT ACCESSING WITH CPUs AND MACHINE PLC. FOUND ETHERNET CABLE DEFECTIVE. OFC COMMUNICATION BETWEEN PLC-CPU TO SERVER ROOM IS NOT HEALTHY. TO BE CHECKED TOMORROW.
PLC-B CPU	MADE ON AND TAKEN AS MASTER. CHECKED ALL RIO PANELS FOR ANY COMMUNICATION ERRORS.
PLC-A CPU	GENIUS BUS COMMUNICATION NOT TAKING PLACE IN ONE LAN. FOUND ONE GBC CARD IS HAVING FAULT. REPLACED CARD WITH SPARE ONE.
TBS	PPM DONE ON MOTORS, PANELS AND FIELD DEVICES. FIELD FEEDBACK CHECKING DONE.ALL MOTORS IR VALUES RECORDED. ALL TB COVERS COVERED WITH COVER.
OC-9A and 11A	WELDING SOCKETS AT H/E and T/E POWER CHECKING AND CLEANING.
OC-11A	FIELD DEVICES FEEDBACK CHECKING DONE.
OC-14A, 15A,16A and 18A	RUNNING INSPECTION DONE AND TEMPERATURES, CURRENTS RECORDED.
OC-19A , OC-21A	RUNNING INSPECTION DONE. CURRENTS and TEMPERATURES RECORDED.