

RASTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT RAW MATERIAL HANDLING PLANT ELECTRICAL GENERAL SHIFT REPORT

Date: 17/06/2025 Area: OHP

Equipment	Job
SB-1 bunker level low interlock	bunker low level interlock for vf-14,15 stoppage is bypassed in om-10 io rack as per operation requirement.
tis-2	checked and restored into circuit.
BRC-5 sandvick	3 icons for CT speed selection are provided in hmi for varying among them.