



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 13/12/2025

Area: IOSA

Equipment	Job
TBS	PCRD CABLE GOT UN-WOUND DUE TO GUIDE CHAIN TENSION UNIT PROBLEM. NOT RECTIFIED BY MECHANICAL TEAM.
OC-27A	PPM DONE ON HT MOTOR . IR VALUES RECORDED
OC-23A	PPM DONE ON HT MOTOR. IR VALUES RECORDED
OC-27A	MAINTENANCE DONE ON HT BREAKER
OC-29A	ALL FIELD DEVICES FEEDBACK CHECKING DONE IN HMI AND PLC.
OC-19A	ALL FIELD DEVICES FEEDBACK CHECKING DONE IN HMI AND PLC.
OC-21A	MAINTENANCE DONE ON HT BREAKER.
BLENDER RECLAIMER	MOVED BACK 120 MTRS TOWARDS OC-15A HEADEND.
OC-19A	PPM DONE ON DE-WATERING PUMPS AND PANELS