



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 21/07/2025

Shift: B

Incharge(s): Amit Roy,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 29	OLR ACTED	RESET	17:50:00	18:00:00	
2	OHP	CO 26	OLR ACTED	RESET	21:20:00	21:30:00	
3	OHP	WOBR-4 on CO-34	LT Auto Forward to be bypassed	LT Auto Bypass done in I/O rack	20:10:00	20:20:00	Operation request given in interlock group
4	CHP	CC 27A	TT DOUBLE INDICATION ON CC39 AND CC40	TT PROPERLY PLACED THEN OK	15:20:00	15:34:00	Operator did not place TT properly at proximity switch
5	CHP	CC 112 SCR 8	NO POWER CHECKED I/C 1 TRIP IN LBDS DUE TO EARTH FAULT IN CC 213 IO PANEL	CC 213 BREAKER RACK OUT THAN I/C 1 AND CC 112 SCR8 POWER CHARGED THAN OK	15:00:00	15:45:00	Snake found in CC-213 panel.NO machine on that bed
6	CHP	CC 31	OLR ACTED	RESET	20:10:00	20:20:00	
7	CHP	CC-222	NOT HEALTHY IN REMOTE SELECTION E/STOP PUSH BUTTON PROBLEM	E/STOP PUSH BUTTON REPLACED WITH NEW	16:40:00	16:50:00	
8	CHP	CC-39	Reported not healthy	Olr acted due to over material on belt.Reset done	21:30:00	21:40:00	
9	CHP	CC-54	Reported not healthy	Olr acted due to over material on belt	15:40:00 20:55:00	15:55:00 21:00:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 21/07/2025

Shift: B

Incharge(s): Amit Roy, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
10	CHP	CC-52	Reported not healthy	OLR acted due to over material on belt	21:00:00	21:10:00	
11	WT	SCO-1A (C) DRIVE	OLR ACTED	RESET	18:30:00	18:40:00	