



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 05/05/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: B

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|----------------|--|---|----------------------|----------------------|-----------------------|
| 1 | OHP | CO 25 | OLR acted | reset done | 16:15:00 | 16:20:00 | |
| 2 | OHP | CO 28 , BRC | BW 2 not running | Chain fallen , informed to operation | 18:10:00 | 18:25:00 | |
| 3 | OHP | BRC on CO 32 | LT brakes not operating | Brakes tight , informed mechanical for adjustment | 19:20:00 | 20:00:00 | No electrical problem |
| 4 | OHP | CO 32 | BRS bypassed | On operation request | 20:20:00 | 20:30:00 | |
| 5 | OHP | CO 34 | Overload acted | reset done | 18:40:00 | 18:50:00 | |
| 6 | CHP | CC 32 | BRS to be bypassed | Bypassed as per operation request | 14:30:00 | 14:40:00 | again kept in circuit |
| 7 | CHP | CC 115 | BRS in bypassed condition | kept in circuit | 17:15:00 | 17:30:00 | |
| 8 | CHP | CC 35 | BRS to be bypassed | Bypassed as per operation request | 20:25:00 | 20:30:00 | IN system |
| 9 | CHP | CC 117 | Tripped in overload | reset done | 18:10:00 19:25:00 | 18:25:00 19:40:00 | |
| 10 | CHP | CC 54 | Tripped in overload | reset done | 21:10:00 | 21:15:00 | |
| 11 | CHP | CC 21 | ZSS cage problem | cage replaced | 19:10:00 | 19:35:00 | |
| 12 | CHP | CC 131 | Tripped in overload | reset done | 21:55:00 | 22:00:00 | |
| 13 | WT | OP 5 | Drive 1 overload | reset done | 20:25:00 | 20:35:00 | |
| 14 | WT | OP 5 | Anti collision sensor frequently acted | Bypassed | 21:20:00 | 21:30:00 | |