



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 02/11/2025

Shift: A

Incharge(s): Lal Singh,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co-26	TRIPPED ON OLR(2TIMES)	RESET DONE	09:40:00 11:50:00	09:50:00 12:00:00	
2	OHP	RSCO-9A (B/D)	TRIPPED ON OLR (2TIMES)	RESET DONE	08:40:00 11:40:00	08:50:00 11:50:00	
3	OHP	CR-1A	NOT RUNNING FOUND LUBRICATION CONTROL MCB TRIP	CONTROL MCB MADE ON THAN OK	10:00:00	10:15:00	
4	OHP	BRC ON CO-8A	REPORTED B/W-2 NOT RUNNING FOUND CHAIN FELL DOWN	INFORMED TO OPERATION	11:05:00	11:15:00	
5	CHP	CC 35	motor trip in overload	reset	06:45:00	06:50:00	4 times
6	CHP	CC 38 SCR6	LT not working,M1,M2 trips due to track jamming	informed operation and reset	08:55:00	09:10:00	
7	CHP	CC 125	OLR acted	reset	09:05:00	09:15:00	
8	CHP	C C 37 SCR7	yard signal missing	LT done than ok	12:00:00	12:15:00	
9	CHP	CC-52	STOPPING ON ZSS CHECKED AND FOUND ZSS PROBE DAMAGED	ZSS PROBE REPLACED THAN OK	07:20:00	07:50:00	
10	CHP	CC-114	TRIPPED ON OLR	RESET DONE	08:40:00	08:50:00	
11	CHP	CC-51	MPD TRIPPED (8TIMES) DUE TO FEEDING CONVEYOR STOP	RESET DONE	07:40:00	13:45:00	
12	WT	OC-1A	OLR ACTED(5TIMES)	RESET DONE	06:30:00	10:30:00	DUE TO JAMMING
13	WT	OP-10	NOT MOVE FOUND R-PHASE NOT COME	POWER RE-CYCLED IN PUSHER THAN OK	09:45:00	10:00:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 02/11/2025

Incharge(s): Lal Singh, K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	IOSA	OC-25 A	TRIPPED ON OLR DUE TO MATERIAL JAMMING	AFTER CLEAR THE MATERIAL RESET DONE	07:00:00	07:40:00	