



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 06/05/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR ON CO 25	B/C NOT RUNNING ZS CAGE STUCK WITH STONE	REMOVED	07:45:00	08:00:00	
2	OHP	CO 35	OLR ACTED	RESET	08:00:00	08:15:00	
3	OHP	CO 51	STOPPING ON ZS BELT OFFCENTRING	INFORMED TO OPERATION	07:00:00	07:15:00	
4	CHP	CC 117	OLR ACTED	RESET	08:10:00	08:15:00	
5	CHP	CC 44	OLR ACTED	RESET	13:30:00	13:35:00	
6	CHP	CC40 SCR 6	TUL C/S NOT WORKING PROBE WIRE GOT CUT	JOINT DONE	07:15:00	07:35:00	
7	CHP	CC40	OLR ACTED	RESET	10:00:00	10:15:00	
8	CHP	CC 107	BRS NOT WORKING	SENSORS CLENED OK	11:00:00	11:15:00	