



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 14/10/2025

Area: WT

Equipment	Job
OT 4 series	Panel and Motor side ppm done
OT 1	Hopper light fittings cleaning done and one 200W LED installed @ AF 2 side
OP 5	Dummy Wagons of OP 6 attached to OP 5, Sensor cable connected in OP 5 and tested,OK
OP 6	D2 Motor re alignment done after bed alignment by Mechanical
OP 1	D6 Motor re alignment done after bed alignment by Mechanical
OP 1,3 and 6	After rake, maintenance done