



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 30/10/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------|--|---|----------|----------|------------------------------------|
| 1 | OHP | wobr on co 25 | yard conveyor zss cage stucked with stone | stone removed | 08:30:00 | 08:50:00 | |
| 2 | OHP | TBS on CO 5A | LT not working,M3 tripped | reset,fwd not working due to jamming,LT rev ok, | 08:20:00 | 08:35:00 | LOcal PB for LT REV to be replaced |
| 3 | OHP | CO 51(B) | olr acted | reset | 07:35:00 | 07:40:00 | |
| 4 | OHP | TBS on co 22 | LT not working,non stacking side boom height not reached | luff up done than ok | 06:45:00 | 06:58:00 | |
| 5 | OHP | co 29 | olr acted | reset | 09:10:00 | 09:20:00 | |
| 6 | OHP | CO 84 | ol acted | reset | 09:40:00 | 09:50:00 | |
| 7 | OHP | RSCO 6a | olr acted | reset | 10:20:00 | 10:30:00 | |
| 8 | CHP | CC 35 SCR3 | b/c not running,zss module problem | bypass in i/o rack | 07:20:00 | 07:30:00 | |
| 9 | CHP | CC 31 SCr 4 | luff not working,oil level low | informed mechanical | 07:25:00 | 07:36:00 | |
| 10 | CHP | CC 105 SCR 10 | LT not working,track jamming | informed operation | 10:00:00 | 10:15:00 | |
| 11 | CHP | CC 37 SCR 7 | LT not working,drive triped | reset | 10:20:00 | 10:30:00 | |
| 12 | CHP | cc 38 scr 6 | IT NOT WORKING,M1 MPCB TRIPPED | made it on | 12:00:00 | 12:10:00 | track jamming,informed operation |



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 30/10/2025

Incharge(s): Saurabh Kumar Yadav

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-----------------|--|------------|----------|----------|---------|
| 13 | WT | OP 10 No power | ACB tripped | made it on | 06:15:00 | 06:30:00 | |
| 14 | WT | OT 1 | d1 tripped in pgf1 fault | reset | 09:05:00 | 09:10:00 | |
| 15 | WT | OT 2 | d1 tripped in pgf1 fault | reset | 11:15:00 | 11:20:00 | 3 times |
| 16 | WT | OP 1 NOT MOVING | ,D6 CONTACTOR GOT WELDED,1A1 ROTOR CONTACTOR AUX BLOCK PROBLEM | BYPASS D6 | 09:20:00 | 10:22:00 | |