



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 15/02/2026

Incharge(s): Amit Roy

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------|-------------------------------------|--|----------|----------|----------------------------------|
| 1 | OHP | CO-1A | Reported ZSS acting | Module problem.Module replaced and tested okay | 09:00:00 | 09:30:00 | |
| 2 | OHP | WOBR on CO-29 | Reported B/W not rotating | OLR acted.Reset done | 09:45:00 | 09:55:00 | |
| 3 | OHP | CO-26 | Reported tripped | OLR acted.Reset done(2 times) | 09:45:00 | 10:55:00 | |
| 4 | OHP | BRC on Co-33M | Reported LT not taking place | PCRD tension acted.Released and tested okay | 11:45:00 | 12:00:00 | |
| 5 | CHP | CC-104 SCR-7 | B/C stopping frequently | ZSS cage stuck with material.Made free and tested okay | 10:35:00 | 10:50:00 | |
| 6 | CHP | CC-105 SCR-10 | Lt not taking place | PCRD cable found totally unwinded laying on ground.Laying done and tested okay | 07:40:00 | 08:00:00 | |
| 7 | CHP | Cc-213 SCR-9 | Reported no operations taking place | ACB in off condition.Made on and tested okay | 10:40:00 | 10:55:00 | Operator pressed E-stop at cabin |
| 8 | CHP | Cc-216 | Reported tripped | OLR acted.Reset done | 10:40:00 | 10:50:00 | |
| 9 | CHP | Cc -108 | Reported tripped | MPD tripped.Reset done and tested okay | 11:55:00 | 12:00:00 | |