



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 27/09/2025

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS ON CO 7A	LT BREAK MPCB TRIPPING FREQUENTLY	CONTACT BYPASSED	22:00:00	22:30:00	
2	OHP	WF4	CONTROL TRIPPING FREQUENTLY	ALL CONTROL CONNECTIONS TIGHTENED THEN OK	00:30:00	01:00:00	
3	OHP	RSCO 1A	Belt drive trip	reset	01:30:00	01:35:00	
4	CHP	SCR 7 ON CC 37	SLEW CHARGE PRESSURE ALARM ACTED	RESET	00:50:00 04:00:00	01:10:00 04:15:00	
5	CHP	SCR 10 ON CC 105	B/C ZSS CAGE STUCK WITH COAL PIECE	REMOVED THEN OK	01:45:00	02:05:00	
6	CHP	SCR 5 ON CC 32 BW NOT RUNNING	BW GOT INTO COAL HEEP	LUFF UP DONE THEN OK	03:20:00	03:40:00	
7	CHP	CC 51	MPD TRIPPED	RESET	00:00:00	03:30:00	
8	WT	OP10 NOT MOVING	EMERGENCY ACTED	RELEASED	00:30:00	00:40:00	