



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 18/11/2025

Incharge(s): Lal Singh,Lal Singh

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-21 TBS	LT NOT WORKING	BREAK STUCK ... RELEASED	14:45:00	15:00:00	
2	OHP	CO-26	TRIPPED ON OLR	RESET DONE	16:30:00 20:00:00 21:15:00	16:40:00 20:10:00 21:25:00	
3	OHP	CO-26 WBR	LT NOT WORKING	IT WAS IN LOCAL KEPT IN REMOTE	16:45:00	16:55:00	
4	OHP	RSCO-9A	ZSS PROBLEM	GAP ADJUSTED	17:00:00	17:15:00	
5	OHP	CO-30	CHUT SENSOR NOT HEALTHY	TB LOOSE IN CARD .. FIXED PROPERLY	21:10:00	21:40:00	NO DELAY
6	OHP	CO-8A BRC	ACB TRIPPED	MADE ON	19:10:00	19:30:00	
7	OHP	CO-112	TRIPPED ON OLR	RESET DONE	20:15:00	20:20:00	
8	OHP	CO-29 WBR	BW TRIPPED	RESET DONE	17:20:00	18:10:00	
9	CHP	CC-219	ZSS CABLE LOOSE	TIGHTENING DONE	15:55:00	16:15:00	
10	CHP	CC-104 SCR-9	SLEW MPD TRIPPED	RESET DONE	19:15:00	19:25:00	
11	CHP	CC-33 SCR-5	PCRD OLR Y AND B PHASE BURNT	REPLACED	16:30:00	17:10:00	
12	CHP	CC-54	MPD TRIPPED 15 TIMES	RESET DONE	16:00:00	21:45:00	
13	CHP	CC-51	MPD TRIPPED 5 TIMES	RESET DONE	17:00:00	21:45:00	