



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 18/12/2025

Area: WT

Equipment	Job
CP 1 and 4	Panel and Motor side ppm done
OP 2	Panel and Motor side ppm done
OP 1,3,6,7 and 9	After rake, maintenance done, OP 9/D5 2 nos bed bolts replaced
CP 2 and 3	After rake, maintenance done
DE system(O)	room lighting done, 2 nos LED tubes replaced
MIS	Resistance (R1 and R2) assembling done for spare brake panel