



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 30/04/2025

Area: CHP

Equipment	Job
CCR	ROUTER switch connected as a gateway between siemens and CCR micrologix, CCR modem is now reconfigured as AP BRDIGE with IP address 172.18.1.102.
CC 51	6 nos BS switches installed , control wiring pending
SCR 5,SCR 6	Cable chamber inspected for cable damage. Boom conveyor cable one core jointed in SCR 6
CM 9	Bus bar maintenance was done
Stacker 2	Slew motor canopy provided,Lower MCC panel blowing done,new Ethernet cable laid and tested slew after mechanical clearance