



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 29/05/2025

Incharge(s): G Eswara Rao

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 29	tripped on olr 4 times	reset done	01:00:00 02:30:00	01:10:00 02:40:00	
2	OHP	co 34	tripped on olr	reset done	01:30:00	01:55:00	
3	OHP	tbs on co 19	lbc not working/olr acted	reset done	22:00:00	22:30:00	
4	CHP	scr 1 on cc 36	slew not working	fault reset done	22:30:00	22:40:00	
5	CHP	scr 2 on cc 34	It not taking place/pcrd cable tension acted	cable tension released	01:00:00	01:15:00	
6	CHP	scr 4 on cc33	It not taking place/pcrd cable tension acted	cable tension released	02:20:00	02:30:00	
7	CHP	scr 1 on cc36	Islewing not taking place/material jamming at slew area	inform to ope.	02:30:00	02:40:00	
8	CHP	scr 7 on cc 39	luffing not working/olr acted	reset done	04:35:00	04:50:00	
9	CHP	cc 203	flap gate signal missing/	signal bypaased at at tb	04:00:00	04:30:00	gate limit to be checked
10	CHP	cc 125	tripped on olr	reset done	01:15:00	01:20:00	
11	CHP	cc 44	tripped on olr	reset	02:20:00 02:50:00	02:30:00 03:00:00	
12	CHP	cc 131	tripped on olr	reset done	04:05:00	04:10:00	
13	WT	op 5 and 6	no power./ACB tripped	acb made on then ok	00:30:00	00:50:00	