



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 10/01/2026

Area: OHP

Equipment	Job
brc -4 on co-28	B/w-1 zss probe fixing plate was welded and restored both B/W ZSS in circuit.