



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 28/04/2025

Shift: A

Incharge(s): V Balaji Naik, Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO 28	ZSS BYPASSED	INFORM TO G SHIFT TO FIX TARGETS	09:00:00	09:30:00	AFTER G SHIFT WORK KEPT IN CIRCUIT
2	OHP	BRC ON CO 31	B/C OLR ACTED DUE TO RETURN SIDE JAMMING	RESET AND INFORMED TO OPRN	11:30:00	11:50:00	
3	OHP	RSCO 9A	NO SUPPLY TO ZSS AND C/S MODULE	BY PASSED AND GIVEN FOR RUNNING	07:30:00	08:15:00	KEPT IN CIRCUIT AT 11:30
4	OHP	CO 51	OLR ACTED	RESET	07:30:00	07:50:00	
5	OHP	CO 17	ZSS FUSE BLOWN IN CONTROL JB	REPLACED	06:35:00	07:30:00	
6	OHP	CO 11A TIS	TRIPPING DUE TO CONVEYOR	BELT OFFCENTRING	09:30:00	09:50:00	
7	CHP	cc 117	OLR ACTED	RESET	09:40:00 11:55:00	09:55:00 12:10:00	
8	CHP	CC 51A	OLR ACTED	RESET	10:50:00	10:55:00	
9	CHP	SCR 5 ON CC 32 LT	DRIVE FAULT	RESET	06:30:00 08:35:00	06:40:00 08:45:00	
10	CHP	SCR 4 ON CC 33	LT DRIVE TRIPPED DUE TO TRACK JAMMING	RESET AND INFORMED TO OPRN	06:50:00	07:00:00	
11	CHP	SCR 9 ON CC 104	SLEW MPD TRIPPED	RESET	09:30:00	09:40:00	



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 28/04/2025

Incharge(s): V Balaji Naik, Nagendra Midde

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	CHP	SCR 9 ON CC 104	OHP SIDE	POSITION MADE HIGH	11:40:00	11:55:00	
13	CHP	S3 ON CC 31 B/C & LUFF	B/C OLR ACTED , LUFF MPCB TRIPPED	OLR RESET, MPCB MADE ON	13:20:00	13:40:00	