



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 12/06/2025

Shift: B

Incharge(s): Saurabh Kumar Yadav

| Sl No | Area | Equipment     | Problem   | Action                                  | From     | To       | Remarks |
|-------|------|---------------|---|---|----------|----------|---------|
| 1     | OHP  | TBS on co 20  | all drive not running,acb tripped,emergency pressed in operator cabin | ACB made on                             | 15:40:00 | 16:00:00 |         |
| 2     | OHP  | CO 9A         | CJD acted   | released                                | 18:20:00 | 18:30:00 |         |
| 3     | OHP  | TBS on co 21  | R b/c not running,olr acted due to material jamming                   | olr reset                               | 18:30:00 | 18:45:00 |         |
| 4     | OHP  | WOBR on co 26 | B/C stopping in zss,zss cage stucked                                  | cage cleaned                            | 19:30:00 | 19:45:00 |         |
| 5     | OHP  | CO 39         | olr acted   | reset                                   | 19:50:00 | 20:00:00 |         |
| 6     | OHP  | TBS on co 21  | r B/c not running,ZSS acted probe damaged                             | probe replaced                          | 21:30:00 | 22:00:00 |         |
| 7     | CHP  | CC 105 SCR 10 | signal missing,b/c not running,lighting complaint mcb tripped         | Plc power recycled,lighting mcb made on | 19:19:00 | 19:35:00 |         |
| 8     | CHP  | CC 36 SCR1    | luffing not working,up limit lever stucked and OLR acted              | up limit released ,OLr reset            | 19:15:00 | 19:30:00 |         |
| 9     | CHP  | CC 36 SCR1    | slew not working,drive trips in ol                                    | reset                                   | 20:50:00 | 21:00:00 |         |
| 10    | CHP  | CC 104 SCR 9  | stacking mode not showing   | loop removed in CM18 for stacking mode  | 14:18:00 | 14:30:00 |         |
| 11    | CHP  | CC 132        | tripped due to olr  | reset                                   | 15:50:00 | 16:00:00 | 2 times |
| 12    | CHP  | CC 131        | olr acted   | reset                                   | 21:20:00 | 21:25:00 | 2 times |