



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 17/05/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WF-3	drive trips in overload	reset it done	03:00:00	03:10:00	
2	OHP	CO 23	olr acted	reset it done	22:30:00	22:35:00	
3	OHP	TBS on Co 24	R luff not working,olr acted	reset	02:00:00	02:15:00	
4	OHP	WOBRon co 6a	b/c not running,cs acted probe position disturbed	probe adjusted	00:05:00	00:31:00	
5	CHP	CC 19(B)	tripped due to OLR	reset	04:30:00	04:35:00	
6	CHP	CC 39 scr 7	B/c not running,found discharge chute full jamming,operation done cleaning,OLr acted	reset it done	23:15:00	23:50:00	first they run in stacking mode for cleaning
7	CHP	SCR 7 CC 39	slew not working,checked electrical ckt healthy,right slew limit acted limit problem,full jamming near slew area	right slew limit bypass	00:03:00	00:08:00	limit slew to be checked
8	CHP	CC 35 SCR 2	LT not taking place,OT acted	OT released	23:50:00	00:05:00	
9	WT	OT 4	no fwd rev movement,side clamp not clamping inhaul side,	electrical side check found ok	22:30:00	23:00:00	informed operation and mechanical