



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 02/09/2025

Area: OHP

Equipment	Job
BRC-4 ON CO-34	CRMP SIDE thruster brake problem is identified, shifted to hvmmc-1 for repair