



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

## VISAKHAPATNAM STEEL PLANT

### RAW MATERIAL HANDLING PLANT

#### ELECTRICAL SHIFT REPORT

Date: 07/01/2026

Incharge(s): Amit Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-29	Reported tripped	OLR acted.Reset done	22:15:00	22:25:00	
2	OHP	WOBR on CO-29	Reported slewing not taking place	Drive tripped.Reset done	23:50:00	00:00:00	
3	OHP	BRC on CO-28	Reported B/W-1 not rotating	Due to jamming	00:10:00	00:26:00	Informed to operation
4	OHP	BRC on CO-28	Reported CT not taking place	Wrong complaint	01:50:00	02:00:00	
5	OHP	CO-16 A	Reported P/C acted	All PC's reset done but still not healthy.Bypassed at Panel	01:45:00	02:15:00	To be checked and to be kept in line
6	OHP	CO-31A	Reported BRS acted	Due to thread pieces.Reset done	22:25:00	22:35:00	Informed to operation
7	OHP	CO-66	BRS acted	Due to thread pieces.	04:40:00	04:50:00	Informed to operation
8	CHP	CC-132	Reported tripped	OLR acted.Reset done(7 times)	23:50:00	05:20:00	
9	CHP	CC-131	Reported tripped	OLR acted.Reset done	01:40:00	01:45:00	
10	CHP	CC-34 SCR-1	LT not taking place	Machine stuck in coal.Drive tripped.Reset done	04:20:00	04:35:00	Informed to operation for cleaning
11	CHP	Cc-39 SCR-6	Slew not taking place	Pump not made on.Pump made on and tested okay	04:30:00	04:45:00	
12	WT	OT-1	Reported tripped	D-1 tripped on PGEF-1 fault.Reset done	22:30:00	22:35:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 07/01/2026

Incharge(s): Amit Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	IOSA	LC-2	I/C-2 tripped(11KV)	Bus coupler made on.Machine power restored and OCR systems made healthy	01:20:00	01:50:00	