



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 15/05/2025

Shift: A

Incharge(s): Lal Singh, Arnab Roy

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|--------------|---------------------------------|---|----------------------|----------------------|------------------|
| 1 | OHP | CO-35 | TRIPPED ON OVER LOAD | RESET DONE | 07:55:00 | 08:00:00 | |
| 2 | OHP | CO-27A | BRS BYPASS REQUEST | BYPASSED IN MODULE | 10:00:00 | 10:10:00 | |
| 3 | OHP | TIS ON CO-25 | TIS FAIL TO START FAULT | FEEDBACK COMING LATE ... RELAY MADE FREE | 09:50:00 13:20:00 | 10:00:00 13:30:00 | INFORMED G SHIFT |
| 4 | OHP | CO-28 BRC | BC NOT STARTING | EMERGENCY PB ACTED ... RELEASED | 09:50:00 | 10:10:00 | |
| 5 | OHP | CO-35 | TRIPPED ON OVER LOAD | RESET DONE | 10:35:00 | 10:45:00 | |
| 6 | CHP | CC-33 S-1 | LT NOT WORKING | DRIVE TRIPPED ON OVER LOAD ... RESET DONE | 08:25:00 | 08:40:00 | |
| 7 | CHP | CC-107 | TRIPPED ON OVER LOAD | RESET DONE | 10:30:00 | 10:35:00 | |
| 8 | CHP | CC-52 | STOPPED ON ZSS AND NOT STARTING | KEPT IN DOL AND AFTER LOAD CLEARING KEPT IN DERIVE AGAIN | 11:00:00 | 11:10:00 | |
| 9 | CHP | CC-114 | TRIPPED ON OLR | RESET DONE | 09:25:00 | 09:35:00 | |
| 10 | CHP | CC-112 SCR-8 | SLEW NOT WORKING | BREAK PRESSER SWITCH PROBLEM.... RECTIFIED BY INSTRUMENTATION | 11:15:00 | 12:15:00 | |
| 11 | CHP | cc-34 scr-2 | luff not working | down limit acted ... released | 13:00:00 | 13:30:00 | |