



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 06/07/2025

Area: OHP

Equipment	Job
brc-4 on co-34	ct reference checked, tightned ai card terminals and restored