



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 16/06/2025

Area: WT

Equipment	Job
OP 1	PANEL AND MOTOR SIDE PPM DONE
OP 7	PANEL AND MOTOR SIDE PPM DONE
MIS	SPARE MOTOR (NEW) RECIVED 37 KW FOR PUSHER
MIS	16 A SP MCB AND 2NOS LED TUBES REPLACED @ MECH.SHIFT ROOM
MIS	LC 10B CLEANING DONE
MIS	SPARE DRIVES BLOWING DONE @NEW BUILDING
MIS	SPARE LOTUS MODEM REPLACED @WT ELEC. SHIFT ROOM
OP 7 and 8	AFTER RAKE MAINTENANCE DONE