



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 08/12/2025

Area: IOSA

| Equipment | Job   |
|-----------|---|
| OC-27A    | CONVEYOR STOPPING ON ZSS FAULT. CHECKED THE PROBE AND MUDULE. BELT NOT ROTATING DUE TO MATERIAL JAMMING.                |
| OJH-8A    | MAINTENANCE DONE ON SLDB AND MCBDB. DEFECTS RECTIFIED.  |
| OC-23A    | LIGHTING CIRCUIT RECTIFICATION IS IN PROGRESS. LIGHTING CIRCUIT RECTIFIED UPTO IDLER-400. SUFFICIENT LIGHTING ARRANGED. |
| MISL      | MOTOR VIBRATION TAKEN FOR CONVEYORS OC-2A, OC-3A, OC-19A AND OC-21A. VALUES RECORDED.                                   |
| OC-11A    | PPM DONE ON MOTOR AND FIELD DEVICES .   |