



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 14/11/2025

Area: IOSA

Equipment	Job
OC-7B	PPM DONE ON MOTOR AND FIELD DEVICES
THRUSTER BRAKES	OPERATION CHECKED AND CHECKED CURRENTS.
TBS	SUPPLY GIVEN TO EM BRAKE OF LT AND CHECKED THE VOLTAGES AND CURRENTS.
OC-7B	POWER HEALTHINESS CHECKED IN ALL WELDING SOCKETS IN OC-7B GALLERY.
WOBR- LnT	IN PCRD CABLE AT TWO PLACES INSULATION DAMAGED. CLOSED WITH INSULATION TAPE.
OC-37A	LIGHTING DEFECTS RECTIFIED AND SUFFICIENT LIGHT PROVIDED.
LBDS-2	LIGHTING DEFECTS RECTIFIED IN LBDS-2 BLDG.
OC-37A	ELECTRONIC BRS REMOVED AND KEPT MECHANICAL BRS IN CIRCUIT.