



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 03/08/2025

Shift: A

Incharge(s): Amit Roy, K SANKARA RAO

| Sl No | Area | Equipment     | Problem   | Action   | From     | To       | Remarks                |
|-------|------|---------------|---|--|----------|----------|------------------------|
| 1     | OHP  | CO-26         | REPORTED RED OLR ACTED                          | OLR RESET  | 06:40:00 | 06:50:00 |                        |
| 2     | OHP  | RSCO-10A(C/D) | NOT TAKING PLACE OLR ACTED                      | RESET  | 07:00:00 | 07:15:00 |                        |
| 3     | OHP  | CO-33M        | REPORTED RED OLR ACTED                          | RESET  | 11:20:00 | 11:30:00 |                        |
| 4     | CHP  | CC-54         | REPORTED RED OLR ACTED                          | RESET  | 09:40:00 | 09:50:00 |                        |
| 5     | CHP  | CC-58         | STOPPING ON ZS FREQUANTLY CHECKED PROBE DAMAGED | ZS PROBE REPLACED THAN OK                        | 09:30:00 | 10:00:00 |                        |
| 6     | CHP  | CC-114        | OLR ACTED                                       | RESET  | 10:30:00 | 10:40:00 |                        |
| 7     | CHP  | CC-28(B/D)    | OLR ACTED                                       | RESET  | 08:35:00 | 08:40:00 |                        |
| 8     | CHP  | CC-111 S-3    | SLEW NOT TAKING PLACE NO PROBLEM                | WRONG COMPLAINT                                  | 06:30:00 | 06:50:00 |                        |
| 9     | CHP  | CC-35 SCR-1   | B/W NOT RUNNING OLR ACTED                       | RESET  | 08:20:00 | 08:30:00 |                        |
| 10    | CHP  | CC-111 S-3    | LT NOT TAKING PLACE M-3 OLR ACTED               | RESET  | 08:10:00 | 08:30:00 | DUE TO TRACK JAMMING   |
| 11    | CHP  | CC-111 S-3    | SIGNAL MISSING                                  | LT TAKEN FWD THAN OK                             | 08:10:00 | 08:30:00 |                        |
| 12    | CHP  | CC 35 SCR-1   | Luffing not taking place                        | Oil level low.                                   | 09:20:00 | 09:45:00 | informed to mechanical |
| 13    | CHP  | CC 34 SCR-2   | LT not taking place                             | PCRD overtension acted. Released and tested okay | 12:10:00 | 12:30:00 |                        |



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 03/08/2025

Incharge(s): Amit Roy, K SANKARA RAO

Shift: A

| Sl No | Area | Equipment | Problem                                    | Action  | From     | To       | Remarks  |
|-------|------|-----------|--|---|----------|----------|--|
| 14    | WT   | OP-8      | Reported Forward movement not taking place | Checked and found OT-4 limits earth fault. Control MCB tripping in I/O rack. Temporary Bypassed and clearance given | 07:30:00 | 08:00:00 | LS4 new cable laid from OT-4 JB to limit switch and limits kept in line at 11.20AM |