



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 02/10/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 35	olr acted	reset	03:30:00	03:35:00	
2	CHP	CC 203 on cc 29	signal missing	loop given in panel tb no 18,19	22:20:00	22:30:00	
3	CHP	CC 32 R1	bc not start,zss cage interlock stuck in coal	cage made free	23:00:00	23:10:00	
4	CHP	CC 31 SCR4	BW not working,oil level low	informed mechanical and operation	02:45:00	02:55:00	
5	CHP	CC 38 SCR6	LT not working, drive tripped	reset	04:40:00	04:50:00	
6	CHP	CC 32 R1	bc not running,cjd acted,jamming	informed operation	00:05:00	00:15:00	
7	CHP	CC 112 scr 8	BC not running	wrong complaint	23:30:00	23:40:00	
8	CHP	CO 15 A	olr acted	reset	23:30:00	23:45:00	
9	WT	OP 10	not moving,d3 motor tb fall down,D5,d4 and d2 tripped	D3 power made off,bypassed,d4,d5 and d2 reset	23:40:00	00:50:00	brake binding informed operation
10	WT	OT 1	D1 and D2 tripped in pgf1 fault	reset	22:30:00	02:30:00	15 times,roller jammed