



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 14/12/2025

Incharge(s): Lal Singh, Lal Singh

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO-31	BW-2 OLR ACTED	RESET DONE	16:55:00	17:05:00	
2	OHP	CO-29	OLR ACTED	RESET DONE	18:55:00	19:05:00	
3	OHP	TBS ON CO-7A	LEFT LUFF NOT WORKING	LIMIT TIED UP ... RELEASED	17:30:00	17:45:00	
4	CHP	cc-51	MPD TRIPPED 5 TIMES	RESET DONE	18:35:00	19:40:00	
5	CHP	CC-54	TRIPPED 5 TIMES	RESET DONE	15:40:00	18:45:00	
6	CHP	RG-2	STOPPING FREQUENTLY WITHOUT FAULT	CONTROL WIRES TIGHTENED	17:30:00	18:00:00	
7	CHP	CC-102	TT CHUT SENSOR NOT HEALTHY	HIGH WIRE LOOSE IN MODULE ... FIXED PROPERLY	14:30:00	14:50:00	
8	CHP	CC-33 R-1	BC NOT RUNNING ... ZSS INTERLOCK CAGE STUCK	RELEASED	18:09:00	18:22:00	
9	CHP	CC-201	OLR ACTED	RESET DONE	18:45:00	18:58:00	
10	CHP	CC-102	ZSS CAGE STUCK	MADE FREE	20:50:00	21:05:00	
11	WT	OP-10	NOT MOVING D6 TRIPPED	RESET DONE	17:25:00	17:30:00	