



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 25/08/2025

Incharge(s): Nagendra Midde,P Venkat Kiran

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co36A	STOPPING on zss	Due to overload at t/e side,	12:20:00	12:35:00	informed operation
2	OHP	co51 beltdrive	tripped on Thermal OLR twice	due to heavy material	07:20:00 09:30:00	07:30:00 09:45:00	reset done after clearing
3	OHP	co51 zss	zss fuse blown at middle jb	due to festoon cable insulation damaged,	10:45:00	11:00:00	taping done and cable rearranged
4	CHP	cc 54	tripped on olr , 6 times	reset done	07:00:00	09:00:00	
5	CHP	cc-51	mpd tripped and feeding conveyor stopped 3 times	reset done	11:00:00	12:30:00	