



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 13/12/2025

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 25	OLR ACTED	RESET	16:50:00 21:15:00	17:00:00 21:20:00	
2	OHP	CO 84	OLR ACTED	RESET	21:30:00	21:35:00	
3	OHP	BRC ON CO 8A	PCRD O/T ACTED	RELEASED	17:00:00	17:15:00	
4	CHP	CC51	FEEDING CONVEYOR OLR ACTED	RESET	15:35:00	15:40:00	
5	CHP	CC 201	OLR ACTED	RESET	14:30:00	14:40:00	
6	CHP	CC 18	ZSS CAGE PROBLEM	REPLACED	17:45:00	18:00:00	
7	CHP	CC 21	ZSS CAGE STUCK	REMOVED THEN OK	20:00:00	20:05:00	
8	CHP	SCR 4 ON CC 31 LT	PCRD CABLE ZIG ZAG DUE TO MECH GUIDE PROBLEM	AFTER MECH CLEARANCE WINDING DONE PROPERLY	14:50:00	15:10:00	
9	CHP	SCT 1 ON CC 34	B/W OLR ACTED	RESET	19:20:00 20:40:00 21:25:00	19:30:00 20:50:00 21:35:00	