



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 05/07/2025

Shift: A

Incharge(s): G Eswara Rao

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	rsco 6a B/D	TRIPPED ON OLR	reset done	07:15:00 08:35:00	07:25:00 08:45:00	
2	OHP	rsco 9a B/D	tripped on olr/jamming	reset done	08:45:00	08:55:00	
3	OHP	co 29	tripped on eocr	reset done	08:40:00	08:50:00	
4	OHP	sb 29a	59% showing even though bunker empty	bypassed for operation requirement	10:30:00	10:50:00	
5	OHP	co 68	brs acting	brs bypassed at module for operation requirement	09:15:00	09:25:00	
6	OHP	co 26	tripped on olr	reset done	10:05:00 11:15:00	10:15:00 11:20:00	
7	OHP	tbs on co 24	right luffing slipping while running due break shoes problem	brakes adjustment done then ok	10:50:00	11:10:00	
8	OHP	TT 4 ON CO 22	forward /reverse not taking place/mpcb tripped	made on	10:30:00	10:40:00	
9	OHP	brc on co 33m	bc not running/olr acted	reset done	12:35:00	12:55:00	
10	CHP	cc 33	tripped olr /due to jamming	reset done 2times	07:30:00	07:40:00	
11	CHP	s1 on cc36	lt not taking place/pcrd power trip	mpcb made on	07:20:00	07:30:00	
12	CHP	scr 1 on cc 35	slew not working/m 2 mpcb tripped	mpcb made on	07:40:00	07:50:00	
13	CHP	cc 223	not running/drive end c/s acted	reset done	08:45:00	08:55:00	
14	CHP	scr 5 on cc 32	lt not taking place/m2 mpcb tripped	mpcb made on	09:00:00	09:10:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 05/07/2025

Incharge(s): G Eswara Rao

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
15	CHP	scr 10 on cc105	bc not runnig/c/s acted dueto jamming	reset done	11:00:00	11:10:00	
16	CHP	cc 203	olr acted in mpd	reset done	12:15:00	12:25:00	
17	CHP	cc 125	tripped on olr	reset done	12:25:00	12:30:00	
18	WT	cc 2 C/D	tripped on olr 2times DUE TO JAMMING	reset done	08:30:00 09:30:00	08:40:00 09:45:00	
19	WT	CP 3	D 5 TRIPPED ON OLR	RESET DONE	11:00:00	11:15:00	