



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 01/05/2025

Shift: C

Incharge(s): G Eswara Rao

| Sl No | Area | Equipment     | Problem                | Action   | From     | To       | Remarks |
|-------|------|---------------|------------------------|--|----------|----------|---------|
| 1     | OHP  | CO 25         | Overload acted         | reset done   | 22:10:00 | 22:20:00 |         |
| 2     | OHP  | WOBR on CO 29 | LT not taking place    | M - 4 tripped due to track jamming. Reset done , informed to operation                 | 22:30:00 | 22:45:00 |         |
| 3     | OHP  | CO 33M        | Overload acted         | reset done   | 22:50:00 | 23:00:00 |         |
| 4     | OHP  | CO 29         | Stopped in ZSS         | ZSS probe wire got cut near neck. Probe replaced                                       | 23:20:00 | 23:45:00 |         |
| 5     | OHP  | WOBR on CO 25 | BC stopping in ZSS     | ZSS wire got cut . Joint done  | 01:50:00 | 02:15:00 |         |
| 6     | OHP  | TBS on CO 20  | Right Luff not working | Brakes not releasing properly mechanically . Informed to mechanical                    | 04:30:00 | 05:00:00 |         |
| 7     | OHP  | VS 4A         | Tripped in overload    | reset done   | 04:30:00 | 04:40:00 |         |
| 8     | OHP  | WOBR on CO 25 | LT not working         | PCRD overtension acted , released  | 05:30:00 | 05:45:00 |         |
| 9     | CHP  | CC 34, SCR 2  | BW not running         | Drive reset  | 00:35:00 | 00:55:00 |         |
| 10    | CHP  | CC 33, SCR 4  | LT not working         | PCRD overtension limit acted , released  | 01:00:00 | 01:15:00 |         |
| 11    | CHP  | CC 40 , SCR 6 | LT not working         | M-2 MPCB tripped. Made on , also coal jamming on GVM side track. Informed to operation | 01:20:00 | 01:30:00 |         |
| 12    | CHP  | CC 34 , SCR 2 | LT not working         | PCRD overtension limit acted . Released, then ok                                       | 04:00:00 | 04:10:00 |         |
| 13    | CHP  | CC 44         | Tripped in overload    | reset done   | 04:55:00 | 05:00:00 |         |



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 01/05/2025

Incharge(s): G Eswara Rao

Shift: C

| Sl No | Area | Equipment | Problem             | Action                                      | From                 | To                   | Remarks |
|-------|------|-----------|---------------------|---|----------------------|----------------------|---------|
| 14    | CHP  | CC 54     | Tripped in overload | reset done                                  | 04:30:00<br>23:15:00 | 04:40:00<br>23:25:00 |         |
| 15    | CHP  | CC 132    | Tripped in overload | reset done                                  | 22:15:00             | 22:30:00             |         |
| 16    | IOSA | FLS wobr  | LT not working      | PCRD overtension acted . Released , then ok | 00:10:00             | 00:20:00             |         |