



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 09/08/2025

Area: WT

Equipment	Job
CP2 and 4	Ground S/S panel maintenance done in LC 10A
OP 1,3,6,7 and 8	Ground S/S panel maintenance done in LC 2A and 2B
OT 1 series	Running Inspection done
EOT(O)	Cabin lighting,circuit problem rectified
OP 1 and 8	After rake maintenance done