



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 19/05/2025

Area: IOSA

Equipment	Job
TBS	FAULTY PULL CHORD REMOVED FROM RIGHT BOOM CONVEYOR AND REPLACED WITH RECTIFIED PULLCHORD.
OC-18A	ZONE-3 PULLCHORDS and BELTSWAY SWITCHES FEEDBACK CHECKED AND COVERED WITH SHEETS.
OC-6A	LIGHTING DEFECTS RECTIFIED
OC-4A	FIELD DEVICES FEEDBACK AND INTERLOCK CHECKING DONE.