



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 29/11/2025

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 29	olr acted	reset	03:17:00	03:26:00	
2	OHP	CO 26	OLr acted	reset	03:20:00	03:30:00	
3	CHP	CC 38 SCR6	LT not working,drive relay o/p not coming,	vfd drive checked IGBT rectifier and inverter unit ok,DC 24 v is also ok,control unit changed than bus fault came	23:40:00	06:00:00	
4	CHP	CC 125	olr acted	reset	02:15:00	05:40:00	5 times
5	CHP	CC 203	olr acted	reset	04:20:00	04:30:00	
6	CHP	CC 51	mpd tripped	reset	01:30:00	01:55:00	3 times