



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 19/08/2025

Area: OHP

Equipment	Job
tbs- on co-20	boom run signal latching is provided, needs to be reset in co-20 popup for healthiness. Indications have been provided for the same.