



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 16/06/2025

Area: IOSA

Equipment	Job
OC-23A	PPM DONE ON MOTOR. IR VALUE CHECKED AND RECORDED.
LBDS-2 RIO	RACK - B STOPPED COMMUNICATING. POWER TO RACK RECYCLED AND GIVEN CLEARANCE.
WOBR-FLS	PPM DONE ON ALL MOTORS. IR VALUES CHECKED AND RECORDED.
OC-27A	PPM DONE ON ZONE-2 and 3 FILED DEVICES. FIELD DEVICES FEEDBACK CHECKED.
OC-21A	PPM DONE ON MOTOR. IR VALUES TAKEN.