



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 30/10/2025

Incharge(s): Saurabh Kumar Yadav

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	wobr on co 25	yard conveyor zss cage stucked with stone	stone removed	08:30:00	08:50:00	
2	OHP	TBS on CO 5A	LT not working,M3 tripped	reset,fwd not working due to jamming,LT rev ok,	08:20:00	08:35:00	LOcal PB for LT REV to be replaced
3	OHP	CO 51(B)	olr acted	reset	07:35:00	07:40:00	
4	OHP	TBS on co 22	LT not working,non stacking side boom height not reached	luff up done than ok	06:45:00	06:58:00	
5	OHP	co 29	olr acted	reset	09:10:00	09:20:00	
6	OHP	CO 84	ol acted	reset	09:40:00	09:50:00	
7	OHP	RSCO 6a	olr acted	reset	10:20:00	10:30:00	
8	CHP	CC 35 SCR3	b/c not running,zss module problem	bypass in i/o rack	07:20:00	07:30:00	
9	CHP	CC 31 SCr 4	luff not working,oil level low	informed mechanical	07:25:00	07:36:00	
10	CHP	CC 105 SCR 10	LT not working,track jamming	informed operation	10:00:00	10:15:00	
11	CHP	CC 37 SCR 7	LT not working,drive triped	reset	10:20:00	10:30:00	
12	CHP	cc 38 scr 6	IT NOT WORKING,M1 MPCB TRIPPED	made it on	12:00:00	12:10:00	track jamming,informed operation



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 30/10/2025

Incharge(s): Saurabh Kumar Yadav

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	WT	OP 10 No power	ACB tripped	made it on	06:15:00	06:30:00	
14	WT	OT 1	d1 tripped in pgf1 fault	reset	09:05:00	09:10:00	
15	WT	OT 2	d1 tripped in pgf1 fault	reset	11:15:00	11:20:00	3 times
16	WT	OP 1 NOT MOVING	,D6 CONTACTOR GOT WELDED,1A1 ROTOR CONTACTOR AUX BLOCK PROBLEM	BYPASS D6	09:20:00	10:22:00	