



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 25/05/2025

Shift: A

Incharge(s): V Balaji Naik,G Eswara Rao

| Sl No | Area | Equipment     | Problem  | Action  | From     | To       | Remarks  |
|-------|------|---------------|--|---|----------|----------|--|
| 1     | OHP  | co 26         | tripped on olr   | reset done  | 10:45:00 | 11:00:00 |  |
| 2     | OHP  | brc on co 30  | bw 1 not running/olr acted                                     | reset done  | 11:00:00 | 11:15:00 |  |
| 3     | OHP  | brc on co 33m | hydrolic pump not running/oil level low                        | inform to ope. and mech   | 12:45:00 | 13:00:00 | /  |
| 4     | OHP  | CO29          | over load trip   | Reset done  | 14:00:00 | 14:00:00 | 02.35pm to 02.40pm   |
| 5     | OHP  | WOBR on CO26  | LT not working found PCRD over tension limit acted             | Released then ok  | 14:00:00 | 14:00:00 | 05.30pm to 05.50pm   |
| 6     | CHP  | CC131         | Over load trip Scraper deflector plate jam( more than 5 times) | Reset done  | 09:16:00 | 09:20:00 | Scraper plate removal is planned after shut down by mechanical |
| 7     | CHP  | CC115         | Running imspection defect rectified                            | One phase incoming cable carbon formed, cable damaged(R phase) MCCB module replaced with 250A | 08:15:00 | 08:35:00 |  |
| 8     | CHP  | cc 125        | tripped on olr   | reset done  | 12:50:00 | 13:00:00 |  |
| 9     | CHP  | CC114         | Tripped due to over load                                       | Reset done  | 06:50:00 | 07:00:00 |  |
| 10    | CHP  | SCR1 on CC36  | Yard motor ZSS kept in ckt, luffing area jamm cleared          | Luffing limit kept in ckt   | 06:30:00 | 06:40:00 |  |
| 11    | CHP  | SCR4 on CC33  | LT not working found PCRD cable over tension acted             | Tension released then ok  | 07:00:00 | 12:07:00 |  |



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 25/05/2025

Incharge(s): V Balaji Naik, G Eswara Rao

Shift: A

| Sl No | Area | Equipment  | Problem   | Action  | From     | To       | Remarks             |
|-------|------|------------|---|---|----------|----------|---------------------|
| 12    | CHP  | S1 on CC34 | LT not working found PCRD over tension acted                | Tension released then ok                      | 07:20:00 | 07:30:00 |                     |
| 13    | CHP  | CC41       | Motor stopping frequently found CJB cable damaged           | Spare cable replaced then ok                  | 09:00:00 | 09:20:00 |                     |
| 14    | CHP  | CC125      | Motor over load MPD trip                                    | Reset done                                    | 12:50:00 | 12:55:00 |                     |
| 15    | CHP  | CC44       | Motor not running MPD trip in over load due to over feeding | Reset done                                    | 13:00:00 | 13:10:00 |                     |
| 16    | CHP  | CC125      | over trip   | Reset done                                    | 14:00:00 | 14:00:00 | 04.47pm to 04.55pm  |
| 17    | WT   | OP9        | Not moving found reached to no power zone at parking area   | By providing jumpers bring back to power zone | 09:30:00 | 09:45:00 | Not a delay no rake |