



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 04/01/2026

Incharge(s): Amit Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-34	Reported tripped	OLR acted.Reset done	07:30:00	07:35:00	
2	CHP	CC-131	Reported tripped	OLR acted.Reset done(2 times)	06:45:00	08:45:00	
3	CHP	Cc-117	Reported tripped	OLR acted.Reset done	09:50:00	10:00:00	
4	CHP	CC-51	MPD acted	Feeding conveyor stopped.Reset done(10 times)	06:50:00	11:30:00	
5	CHP	CC 104 SCR-9	Slew not taking place	Contactorauxiliary contact stuck.Rectified and tested okay	07:40:00	08:25:00	
6	CHP	Cc-39 SCR-6	Slew not taking place	Limit acted.Slew reverse done(2 times)	11:45:00	13:30:00	
7	WT	OT-2	Reported tripped	Drive-1 tripped on PGEF-1 fault.Reset done	11:35:00	11:40:00	
8	IOSA	OC-25A	Reported tripped	OLR acted.Reset done	08:00:00	08:15:00	