



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 17/05/2025

Area: WT

Equipment	Job
CO 2(Belt)	Bed slots cutting and Alignment done, trail run taken after Mech. clearance, OK
CO 2(Belt)	Gear box changing done by Mech. motor coupling removed and new type coupling fixed
OT 3 series	panel and motor side ppm done
OP 7	panel and motor side ppm done
OP1 and 3	after rake maintenance done