



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 17/12/2025

Incharge(s): G Eswara Rao

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|----------------|---|-----------------------------|----------------------|----------------------|---------|
| 1 | OHP | co 25 | tripped on olr. | reset done | 11:40:00 | 11:50:00 | |
| 2 | OHP | jh -2 | hoist not working./no power /tripped at LC -3 | MPCB made on.then ok | 11:30:00 | 11:40:00 | |
| 3 | OHP | co 25 | tripped on olr | reset done | 08:50:00 | 09:00:00 | |
| 4 | OHP | co 29 | tripped on olr | reset done. | 12:30:00 | 12:40:00 | |
| 5 | CHP | cc 26 | brs acted due belt peices | reset done. | 07:30:00 | 07:40:00 | |
| 6 | CHP | scr 2 on cc40 | b w not working/bw stuckup with iron sheet. | informed to mech. and ope., | 11:00:00 | 11:10:00 | |
| 7 | CHP | scr 9 on cc104 | slew not working/pb loose | pb tighten .then ok | 11:00:00 | 11:10:00 | |
| 8 | CHP | cc 40 | tripped on olr | reset done. | 11:22:00 | 11:27:00 | |
| 9 | CHP | cc 51 | md tripped on olr 2 times | reset done. | 09:10:00 | 09:15:00 | |
| 10 | CHP | cc 54 | tripped on olr | reset done | 08:10:00 13:02:00 | 08:15:00 13:07:00 | |