



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 21/10/2025

Area: WT

Equipment	Job
CO 2 side	stair case lighting problem rectified
OT 4	200W LED fitting installed for visualization of clamp/ de clamp
OP 2	Panel side ppm including contactor core cleaning done
OP 2 and 5	After rake maintenance done