



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 21/09/2025

Shift: A

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TT-4	REPORTED LT NOT WORKING CHECKED AND FOUND MPCB TRIP	MADE ON THAN OOK	07:00:00	07:15:00	DUE TO JAMMING
2	OHP	TBS ON CO-7A	REPORTED BOTH B/C S NOT RUNNING CHECKED AND FOUND RB/C JAMMING LB/C CONTROL MCB TRIP	CONTROL MCB MADE ON THAN OK	07:15:00	07:35:00	
3	OHP	CO-26	OLR ACTED	RESET DONE	08:15:00	08:25:00	
4	OHP	BRC ON CO-28	LT NOT TAKING PLACE PCRD O/T ACTED	RELEASED	08:15:00	08:30:00	
5	OHP	WOBR ON CO-6A	LT NOT TAKING PLACE M-2 OLR ACTED	RESET DONE	11:30:00	11:45:00	
6	OHP	CO-9	OLR ACTED(2TIMES) DUE TO MATERIAL JAMMING	AFTER CLEAR THE MATERIAL IN LOCAL MODE THAN OLR RESET DONE	11:50:00	12:10:00	
7	OHP	CBMS -4A ON CO-2A	REPORTED STOPPING ON ZS CHECKED AND FOUND ROD STUCK WITH BELT	ROD REMOVED THAN OK	12:10:00	12:20:00	
8	OHP	CO-29	OLR ACTED	RESET DONE	13:15:00	13:25:00	
9	OHP	CBMS -4A	FREQUENTLY STOPPING	BY PASSED OPERATION REQUIREMENT	13:30:00	13:40:00	
10	CHP	CC--51	OLR ACTED (3TIMES) DUE TO FEEDING CONVEYOR	RESET DONE	07:40:00	07:45:00	
11	CHP	CC-32	OLR ACTED	RESET DONE	10:50:00	11:10:00	
12	CHP	CC-36 SCR-1	LUFFING NOT WORKING CHECKED AND FOUND DOWN LIMIT ACTED	DOWN LIMIT BYPASSED AFTER PLACE THE POSITION THEN LIMIT KEPT IN CIRCUIT	11:00:00	11:20:00	