



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 15/06/2025

Shift: C

Incharge(s): Lal Singh, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 34	OLR acted	reset done	03:50:00	03:55:00	
2	OHP	CO 8A , BRC	BC overload acted	reset done	23:55:00	00:15:00	
3	OHP	VF 23	MPCB tripped in panel and LC 6	Motor meggar done , found okay and tested	22:50:00	23:20:00	
4	OHP	CO 43A	Pull chord acted	Tail end right side one pull chord switch problem , switch bypassed	01:00:00	01:20:00	
5	OHP	CO 33M BRC	Hydraulic pump not starting	Oil level low, informed to operation	00:15:00	00:30:00	
6	OHP	BRC on CO 32	CT not working	Operator cabin side limit switch getting stucked frequently . greasing done , then okay	00:15:00	00:40:00	
7	CHP	CC 39	Tripped on overload ( 3 times)	reset done . found jamming in tail end side , informed to operation	22:30:00	05:15:00	
8	CHP	CC 223	Not running	Found that chute sensor acted due to jamming . Informed operation for cleaning	00:00:00	00:30:00	
9	CHP	CC 44	Tripped on overload ( 2 times)	reset done	01:00:00	03:20:00	
10	CHP	CC 201	OLR acted	reset done	04:15:00	04:25:00	
11	CHP	CC 39 , SCR 7	LT not working .	Drive tripped on overload , reset done	01:05:00	01:20:00	
12	CHP	CC 34 , SCR 2	Slew and LT not working	Slew healthy and running . LT PCRD overload acted, reset done	23:40:00	00:05:00	
13	CHP	CC 105 , SCR 10	Lights not glowing	In operator cabin AC MCB tripping , made off . Then remaining MCB s made on.	23:10:00	23:35:00	



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 15/06/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC 26	BRS kept in circuit	done	22:50:00	23:00:00	
15	WT	CP 1 to CP 4	Communication problem	Power recycled	05:15:00 22:15:00	05:20:00 22:20:00	